

CERTIFICATE OF CONFORMITY

No. AT5257180-1

1. Applicant

Applicant : Mr Rodolphe ARGOUD

Company Name : VERTIC SAS - 691 Chemin des fontaines – CIDEX 8F 38190 Bernin, France vertic@vertic.fr

2. Considered Equipment

Manufacturer : VERTIC

Reference : ALTILIGNE type life line with new ABS55 energy absorber

Type of equipment : NF EN 795 Standard Class C – September 1996

3. Description

Main characteristics:

- The anchoring system is designed to be used by 3 people at a time
- Maximum range : 12 metres
- Minimum range : 4.5 metres
- Cable tension : 80 daN or 50 daN on ALTIFIX wall bracket
- Maximum allowed angle : the line must be horizontal and can be used in the floor, wall and ceiling position
- Bend : with
- Energy absorber : with

Components :

- Pre-stretcher – Tension : 80 daN - reference : PND
- Pre-stretcher – Tension : 50 daN - reference : PND_50
- Manual stretcher - reference : TSL2
- Stretcher to crimp - reference : TSL3
- Articulated end to crimp - reference : ES2
- Manual end – reference : EC
- Angle parts – reference : ANG / A90 / A135
- Fixed intermediate part – reference : IFR90
- Mobile intermediate part – reference : IMR
- Energy absorber – reference : ABS55
- Stainless steel 8 mm dia. cable Type 7x7 – reference : CI8
- Identification panel – reference : PS
- Mobile carriages – reference CMS3 / CMS3-KR / CMB / CMBR

Detailed description in the technical file of the Altligne Life Line Version 2010 written by Sylvain MANON (VERTIC SAS)

4. Referential

The anchoring system was evaluated according to the NF EN 795 standard of September 1996 in the C class. This evaluation includes the following phases :


- Design control
- Static resistance tests
- Dynamic performance tests
- Dynamic resistance tests
- Calculation note check
- User manual check
- Installation manual check
- Marking check

Detailed description in the test reports 20311228-001-1 and 5257180-001-1.

5. Conclusion

The "ALTILIGNE class C anchoring system with new ABS55 energy absorber" conforms to the relevant requirements of the NF EN 795 standard of September 1996.

Date : 15th july of 2010


Guillaume QUINTIN
Contract Manager

This certificate is a one (1) page document made in two (2) original copies handed over to the applicant. No duplicate copy will be delivered.

This certificate does not constitute the proof provided for by the consumer code (article L-115-27) by which an agency independent of the manufacturer certifies that the commercial objectives of a product conform to the characteristics in a referential filed with the administrative authority.

CETE APAVE SUDEUROPE

French Simplified Share Holder Company (Ltd) with a capital of € 3 060 000 - SIREN No. : 775 581 812 – Internet Site : www.apave.com
Tenant/Managing Agent of the goodwill (business) of CETE APAVE Lyonnaise

LYON

177 route de Sain Bel
BP 3

69811 TASSIN CEDEX

Tel : 04 72 22 52 52 - Fax : 04 72 22 52 00

HEAD OFFICE MARSEILLE

8 rue Jean-Jacques Vernazza
Z.A.C. Saumaty-Séon – BP 193

13322 MARSEILLE CEDEX 16

Tel : 04 98 15 22 80 - Fax : 04 98 15 22 81

BORDEAUX

Z.I. avenue Gay Lussac
BP 3

33370 ARTIGUES-près-BORDEAUX

Tel : 05 56 77 27 27 - Fax : 05 56 77 27 00